



GRANGER-HUNTER
IMPROVEMENT DISTRICT

2888 South 3600 West • P.O. Box 701110 • West Valley City, Utah 84170-1110 • Phone (801) 968-3551 • Fax (801) 968-5467 • www.ghid.org

GHID General Notes

A) General notes for all plans

1 Project shall comply with all Granger-Hunter Improvement District specifications and requirements.

2 Project shall comply with all Utah Division of Drinking Water rules and regulations including, but not limited to, those pertaining to Backflow Protection and Cross Connection Prevention.

B) Note for all plans with exterior water or sewer piping

3 All construction in the Culinary Waterline and Sanitary Sewer Line pipe zone shall comply with all Granger-Hunter Improvement District specifications and requirements.

C) Note if the project has a grease interceptor

4 A dye test of the sanitary and grease sewer lines is required and shall be conducted prior to Granger-Hunter Improvement District Final acceptance.

D) Note if the project does not need a grease interceptor

5 At the time of the GHID Final Review of these plans, this project was not categorized as an Industrial User. However, all Fats, Oils, Greases, and Sands Dischargers shall be connected to an outdoor 1,000 gallon (minimum) Grease Interceptor and Sampling Manhole. Only one Sampling Manhole is allowed per parcel owner, or culinary water meter and bill. Therefore, should this project be modified or its use change, GHID may require pretreatment infrastructure be installed at the sole cost of the parcel owner.